

# TECHNICAL DESCRIPTION

## INDUSTRIAL CONTROL



worldskills  
international

© WorldSkills International  
TD19 v4.0 – WSC2013

WorldSkills International, by a resolution of the Technical Committee and in accordance with the Constitution, the Standing Orders and the Competition Rules, has adopted the following minimum requirements for this skill for the WorldSkills Competition.

The Technical Description consists of the following:

<b>1.</b>	<b>INTRODUCTION .....</b>	<b>2</b>
<b>2.</b>	<b>COMPETENCY AND SCOPE OF WORK .....</b>	<b>2</b>
<b>3.</b>	<b>THE TEST PROJECT .....</b>	<b>4</b>
<b>4.</b>	<b>SKILL MANAGEMENT AND COMMUNICATION.....</b>	<b>10</b>
<b>5.</b>	<b>ASSESSMENT .....</b>	<b>11</b>
<b>6.</b>	<b>SKILL-SPECIFIC SAFETY REQUIREMENTS.....</b>	<b>14</b>
<b>7.</b>	<b>MATERIALS &amp; EQUIPMENT .....</b>	<b>14</b>
<b>8.</b>	<b>MARKETING THE SKILL TO VISITORS AND MEDIA.....</b>	<b>16</b>

Effective 11.10.11



John Shiel  
Chair Technical Committee



Stefan Praschl  
Vice Chair Technical Committee

© WorldSkills International (WSI) reserves all rights in documents developed for or on behalf of WSI, including translation and electronic distribution. This material may be reproduced for non-commercial vocational and educational purposes provided that the WorldSkills International logo and copyright notice are left in place.

## 1. **INTRODUCTION**

### 1.1 **Name and description of skill**

1.1.1 The name of the skill is

Industrial Control.

1.1.2 Description of skill

Industrial Control covers elements from electrical installation and automation installation, although the requirements are now leaning more and more towards automation installation. The current mix of categories includes Electrical Installation and Mechatronics, a field covering automation installations for component manufacture.

The category requirements include the basics of electrical and automation installation including conduits, cables, devices, instruments, automated devices and control centre fittings quickly and safely, and implementation of the assemblies safely. Designing of circuits and parameters, and programmes and implementation of frequency transformers and programmable logic are common tasks for this skill. Troubleshooting for relay control and logic programmes is also a common practice.

### 1.2 **Scope of application**

1.2.1 Every Expert and Competitor must know this Technical Description.

1.2.2 In the event of any conflict within the different languages of the Technical Descriptions, the English version takes precedence.

### 1.3 **Associated documents**

1.3.1 As this Technical Description contains only skill-specific information it must be used in association with the following:

- WSI - Competition Rules
- WSI - Online resources as indicated in this document
- Host Country - Health and Safety regulations

## 2. **COMPETENCY AND SCOPE OF WORK**

The Competition is a demonstration and assessment of the competencies associated with this skill. The Test Project consists of practical work only.

### 2.1 **Competency specification**

#### **Health and safety**

Competitor must know and understand:

- Competitor must know and understand the safety regulations of the Host Country and the WorldSkills Health and Safety minimum requirements.
- Test and Commissioning procedure
- Safe working methods in fault finding and when using measuring equipment
- What kind of the personal safety clothes and equipment must be used at different working phases and when using electrical tools

Competitors shall be able to:

- Work 100% safely during the competition.
- Use right Personal Protective Equipment (PPE)
- Test and commissioning in practice
- Fill the T&C documentation
- Safe working at fault finding
- Inform the Workshop Supervisor about the possible safety risks and damaged materials or components which could cause the safety risk

#### **Circuit design and/or modification**

Competitor must know and understand:

- Symbols and components of the relay based circuit diagrams (IEC 60617)
- Basic principles and functions of the relay/contactor controlled circuits

Competitors shall be able to:

- Draw corrections / additions / plan on blank or prefilled paper according to the nonverbal function description and given a copy of the drawing standard sections (IEC 60617) that they are to use.
- Think logically and work systematically

#### **Making of the Automation Control Panel/Centre**

Competitor must know and understand:

- Reading of the layouts, circuit diagrams, terminal drawings, function descriptions and operation manuals
- Basic working methods for the sheet metal (drilling, cutting square or round holes, fixings)
- Use of the mechanical/electrical tools

Competitors shall be able to:

- Install the ducts, terminals, components and wiring of the control panel according to the drawings and given tolerances
- Label all components and cables as per drawings

#### **Field Installations**

Competitor must know and understand:

- Installation of the field components,
- Technical drawings of the Test Project: layout of the wall installation, layout of the control panel, circuit diagrams and flow charts,
- Principles and functions of all components in the material list
- Working methods for different parts of Test Project

Competitors shall be able to:

- Measure the correct positions for the components to be installed
- Make component installations in right order
- Prepare and install the wire-ways within given tolerances
- Installation of the field components,
- Safely use all tools without risk to themselves or others around them

#### **Programming of the Automation equipments of the Test Project**

Competitor must know and understand:

- Non-Verbal Function Descriptions (like in the Pre-Project)
- How to control motors, valves, and other objects listed in the material list with PLC VSD-functions
- HMI and PC-based HMI/Visualisation to interact with the PLC Code (No scripting or programme automation in the HMI) Input limits can be set in the HMI
- The control program can be made any way the competitor chooses using the supplied equipment (PLC, HMI, VFD/VSD or distributed IO processor)

- I/O-Distribution based on Bus Techniques (At Leipzig 2013 Profibus or Profinet)
- Sequence-programming methods

Competitors shall be able to:

- Create program according to the Non-verbal Function Description
- Configure the HMI-screens according to the non-verbal function description
- Configure the VSD as required in the function description
- Test the functions safely
- Show the functions to the evaluation groups

### **Fault finding**

Competitor must know and understand:

- Safety risks and Instructions in fault finding
- Circuit Diagrams and nonverbal function descriptions
- Principles of the Relay Control Fault Finding with multimeter
- Components and symbols of the relay based circuit diagrams
- Basic principles and functions of the common Industrial relay/contactors Control Circuits and Main Circuits
- Meaning of the logical thinking
- Note: Competitor gets the correct diagrams for the fault finding panel with the main project (no faults shown)

Competitors shall be able to:

- Analyse the right functions of the fault finding process/control cabinet
- Recognise the wrong functions
- Localise the right positions of the faults to the drawings with multimeter

## **2.2 Theoretical knowledge**

2.2.1 Theoretical knowledge is required but not tested explicitly.

- Theoretical knowledge is limited to that necessary to carry out the practical work, the programming of electronic and electromechanical components, reading and interpretation of drawings, sketches or schematic diagrams.
- Knowledge of material and processes.

2.2.2 Knowledge of rules and regulations is not examined.

## **2.3 Practical work**

The Competitor must independently carry out the requirements for the modules described in subsection 3.2 Test Project design requirements using commercially available material and equipment, which must be installed and wired into an installation in accordance with the documentation provided.

Competitors must use the necessary and appropriate working techniques to complete the installation.

Any materials-related requirements or manufacturers specifications shall be provided to the Competitor at the same time as the Test Project.

# **3. THE TEST PROJECT**

## **3.1 Format / structure of the Test Project**

The main Test Project which includes the PLC programming component is designed and assessed in a modular format.

Circuit design and fault finding are standalone modules

The following table shows the duration and location of the modules.

Module	Name	Approx. hours	Place
A	Main project	16	Panel A and B simulation
B	PLC programming and configuring the BUS-system	4	At workbench on computer
C	Circuit design and/or modification	1	At the Booth
D	Fault finding hardware	1	Away from booth
Total =		22	

Commissioning is embedded in the main Test Project.

### 3.2 Test Project design requirements

The Test Project must meet the following requirements:

- The Test Project must be modular
- Be in accordance with the current Technical Description.
- Be a Computer Assisted Drawing (CAD) to ISO-standards supplied in digital format (in AutoCAD .dwg format) and in hard copy
- Contain a standard legend
- Be self explanatory requiring a minimum of translation
- Include measurements for the installation of materials and equipment from the horizontal and vertical datum (or reference) lines
- Soft copies of text documents must be provided in Microsoft Word format.

With reference to the material specifications - see paragraph 3.10. The Test Project may include any of the following sub-modules. Any sub-module must be integrated into the overall function of the installation or module concerned.

- Installation of signal/control/power circuits (heat, motors etc. e.g. pumpstation, boiler control and similar industrial applications)
- Testing and commissioning of wiring and relay logic
- PLC, HMI, and VSD installation and I/O wiring
- PLC, HMI, VSD installation and I/O wiring
- Installation of the Distributed I/O-system and cabling
- Testing and commissioning of PLC, HMI and VSD programs

The appropriate technical skills are:

- Measuring and marking of installation materials and equipment
- Measuring and installing equipment and pipes
- Sawing, drilling, and de-burring
- Working with and assembling materials made from metal and plastic
- Wiring and connecting switches, control devices and consumer appliances

## Module A – Main Project

The main Test Project will consist of four (4) main elements:

1. The installation and wiring element (power and control), which includes:
  - The assembly of and construction of components commonly used in the industry
  - Installation of control panels and boxes
  - Installation of wiring systems
  - Installation of wiring and cabling
  - Terminations and connections
  
2. Testing and commissioning of wiring and relay logic in which the following tests are to be completed:
  - Insulation resistance between phases, phases to neutral, phases to earth, and neutral to earth. The resistance must be equal or more than 1 MΩ when tested at 500V d.c. with an insulation resistance tester.
  - Earth continuity resistance – The maximum resistance between the main incoming earth and any point on the installation required to be earthed may not be more than 0.5 Ohm tested with a continuity tester.
  - Individual loads used for Test Projects shall not exceed 1 kW. The total load shall not exceed 2 kW.
  - Polarity of socket outlets when viewed from the front (looking at the pins) shall be:
    - Single-phase – clockwise from the earth pin: (L1-N)
    - Three-phase – clockwise from the earth pin: (L1-L2-L3-N)
  - Polarity of switches and circuit breakers
  - Voltage tests – correct voltages to be measured between conductors at any point in the circuits
  - Electrical safety
  - Correct wiring to specification
  - Commissioning
    - Faults identified and corrected
    - Live testing completed
    - Function to specification
  
3. PLC installation and I/O wiring
  - Mounting and wiring of the PLC
  - I/O wiring and termination
  - Segregation of power, analogue and digital inputs and outputs
  
4. Testing and commissioning of I/O wiring, PLC program, VSD setup and HMI configuration
  - PLC communication to HMI, VSD and PC
  - I/O wiring in accordance with I/O addresses
  - Program testing and commissioning

In the event that standard colour codes for wiring cannot be made available by the Competition Organiser, the Experts are to select other colours for use by the Competitors. Sufficient colours must be available as required by the Test Project.

An external electrical supply must be available for testing communication between the PC and PLC prior to commencement of the Competition and for programming during the Competition (if required).

## **Module B – PLC Programming and HMI Configuration**

1. The PLC program must conform to IEC 1131.3 and be programmed using only the following instructions:
  - Bit level instructions – NO, NC, Transitional, Coils, Jumps, Calls, Sets and Resets,
  - Math instruction – ADD, SUBTRACT, MULTIPLY, DIVIDE
  - Word level instruction – MOVE, COMPARE, BCD, AND, OR
  - Basic instruction – TIMERS, COUNTERS, REGISTERS
  - File control – The Competitor will decide on how they will write the program and which of the listed PLC instructions he will use.

No other programming methods are to be used.

2. All information about the requirements of the program functions must be given equally to all Competitors. Basically all the information must be at the non-verbal function description.
3. Competitors are not allowed to help each other during the programming module at the working booths.
  - All programming and configuration must satisfy module B specification.
  - The HMI is limited to display and pushbutton controls only.
  - The VSD is limited to basic controls with digital and analogue signals.

## **Module C – Circuit Design and/or Modification**

1. The Competitor is required to design/modify a relay logic, control and/or power circuit diagram using no more than the listed components (within this Technical Description) in accordance with a specification and/or the functional diagram.
2. The design will be marked on:
  - Functional requirements being met
  - Economy of design
  - Accurate use of symbols
  - Accuracy of design
  - Provision of a legend
  - 60% of marks for this section will be awarded for correct functioning.

## **Module 'D' – Relay Logic Fault Finding – in existing plant (or system)**

1. Relay logic fault finding on a given panel
  - The Competitor is required to find five introduced faults within a control and/or power circuit.
  - The Competitor is provided with the circuit diagram and may see an operational circuit before the faults are introduced.
  - Using a multimeter the Competitor shall test the panel & identify the faults on the form provided. The form may consist of the circuit diagram, or a function diagram, or a developed form.
  - The Competitor must identify the type of fault and fault location.
  - All faults must be identified on the document(s) provided.
  - A Competitor may return to an earlier fault within the one-hour period.
  - Fault documents completed by the Competitors should indicate: Competitor's name, country/region, and fault test panel number.
2. Design specification for relay logic fault finding
  - Three circuits are to be submitted from different countries/regions to the Chief Expert, who will select one to be constructed by the Competition Organiser for the fault finding test.
  - The chosen circuit drawings will be circulated at the same time as the main project. So each Competitor must understand the functions of the circuits.



- The Competition Organiser will construct sufficient identical test panels for the number of Competitors to complete in one day.
- The type of faults will be selected by the Expert team selected for supervising and marking this module at the WorldSkills Competition 3 hours before the fault-finding module starts.
- The Expert group will locate possible faults, 2 per Expert and the Workshop Supervisor organises the lottery on the same morning when the module will start. The Chief Expert will draw the fault number and the Workshop Supervisor will install that fault. Duplicate faults will count as one.
- Faults must be introduced in the same order for all Competitors.
- Only one fault is introduced for each test.
- Marks are awarded for each fault identified.
- Bonus marks may be awarded for finding individual faults within a given time.
- Bonus marks may be awarded for finding all faults.

### 3. Circuit specifications

The test circuit includes:

- Timers
- Switches or pushbuttons
- Relays
- Contactors with 2xNO and 2xNC auxiliary contacts
- Simulated loads

### 4. Types of faults

Faults should be selected from the following list:

- Open circuit
- Short circuit
- Incorrect timer setting
- Incorrect overload setting
- Only one fault is to be applied per test.

The Experts may allocate marks based on the time taken to find each or all faults by making marking points for finding a fault in less than a given time or times. (Accurate timekeeping is essential so a stop watch or similar must be provided for this purpose.)

## 3.3 Test Project development

The Test Project MUST be submitted using the templates provided by WorldSkills International (<http://www.worldskills.org/competitionpreparation>). Use the Word template for text documents and DWG template for drawings.

### 3.3.1 Who develops the Test Project / modules

The Test Project / modules are developed by:

The Test Project/modules are developed by the Chief Expert and three Experts selected by vote at the previous Competition, and must be validated as defined in paragraph 3.5.

### 3.3.2 How and where is the Test Project / modules developed

The Test Project / modules are developed:

○ Jointly on the Discussion Forum.

### 3.3.3 When is the Test Project developed

Time	Activity
At the previous Competition	Experts to be involved in the Test Project development team are selected by vote.
12 months before the Competition	The Test Project is developed.
6 months before the Competition	The Chief Expert sends the Test Project to the Technical Director.
6 months before the Competition	The Test Project is circulated on the WSI website.
At the Competition	30% change is made to the Test Project

### 3.4 Test Project marking scheme

Each Test Project must be accompanied by a marking scheme proposal based on the assessment criteria defined in Section 5.

3.4.1 The marking scheme proposal is developed by the person(s) developing the Test Project. The detailed and final marking scheme is developed and agreed by all Experts at the Competition.

3.4.2 Marking schemes should be entered into the CIS prior to the Competition.

### 3.5 Test Project validation

It must be demonstrated that the Test Project modules can be completed within the material, equipment, knowledge and time constraints. This will be demonstrated by written confirmation by one or more Experts.

### 3.6 Test Project selection

The Test Project is selected as follows:

The Chief Expert and the three selected Experts will develop a project in accordance with the current Technical Description for the next WorldSkills Competition. The selection of the Test Project content is solely made by these four Experts.

### 3.7 Test Project circulation

The Test Project is circulated via WorldSkills International website as follows:

The Test Project is circulated via WorldSkills International website a 6 months prior to the Competition.

### 3.8 Test Project coordination (preparation for Competition)

Coordination of the Test Project will be undertaken by:

Three Experts will be selected by vote at the previous Competition to work with the elected Chief Expert to develop a Test Project in accordance with the current Technical Description for the next Competition.

The Chief Expert will be responsible for ensuring that:

- The circuit designs are accurate and complete.
- There are no installation requirements that cannot be completed.
- The tasks can be completed in the prescribed time of 22 hours.
- Proper function is achievable.
- The material list is accurate.
- Competitor instructions are kept to a minimum of text. Flow charts or functional diagrams may be used.
- The project is complete in all aspects.

- The Chief Expert will forward the completed Test Project to the Technical Director six (6) months before the current Competition so that material availability can be confirmed with the Competition Organiser.
- The Chief Expert will ensure that all required communication occurs between all Experts and participating Members.

### **3.9 Test Project change at the Competition**

The 30% change will be selected and agreed by vote of all Experts prior to the commencement of the Competition. The changes will normally be of the software type.

The panel of Experts who developed the Test Project should also propose 30% changes. Part or all of the 30% change can also be proposed by any other Experts at the Competition. The changes must be agreed by majority vote of the Experts at the Competition.

### **3.10 Material or manufacturer specifications**

The Test Project should be constructed from commercially available materials. When materials in the Host Country are not readily available in other countries/regions, then samples of these materials must be sent to each Competitor 6 months prior to the commencement of the Competition. The Workshop Supervisor will confirm if this is necessary.

## **4. SKILL MANAGEMENT AND COMMUNICATION**

### **4.1 Discussion Forum**

Prior to the Competition, all discussion, communication, collaboration and decision making regarding the skill must take place on the skill-specific Discussion Forum (<http://www.worldskills.org/forums>). All skill-related decisions and communication are only valid if they take place on the forum. The Chief Expert (or an Expert nominated by the Chief Expert) will be moderator for this forum. Refer to Competition Rules for the timeline of communication and competition development requirements.

### **4.2 Competitor information**

All information for registered Competitors is available from the Competitor Centre (<http://www.worldskills.org/competitorcentre>).

This information includes:

- Competition Rules
- Technical Descriptions
- Test Projects
- Other Competition-related information

### **4.3 Test Projects**

Circulated Test Projects will be available from [worldskills.org](http://www.worldskills.org) (<http://www.worldskills.org/testprojects>) and the Competitor Centre (<http://www.worldskills.org/competitorcentre>).

### **4.4 Day-to-day management**

The day-to-day management is defined in the Skill Management Plan that is created by the Skill Management Team led by the Chief Expert. The Skill Management Team comprises the Jury President, Chief Expert and Deputy Chief Expert. The Skill Management Plan is progressively developed in the six months prior to the Competition and finalised at the Competition by agreement of the Experts. The Skill Management Plan can be viewed in the Expert Centre (<http://www.worldskills.org/expertcentre>).

## 5. ASSESSMENT

This section describes how the Experts will assess the Test Project / modules. It also specifies the assessment specifications and procedures and requirements for marking.

### 5.1 Assessment criteria

This section defines the assessment criteria and the number of marks (subjective and objective) awarded. The total number of marks for all assessment criteria must be 100.

Section	Criterion	Marks		
		Subjective (if applicable)	Objective	Total
A	Circuit design and/or modification	0	10	10
B	Fault finding - Hardware	0	10	10
C	Measurement	0	15	15
D	Installation wall and panel	0	30	30
E	Test, commissioning and safety	0	5	5
F	Hardware Function (Manual operation/wiring and function of the Bus-system)	0	10	10
G	Software Function (Automatic operation)	0	20	20
<b>Total =</b>		<b>0</b>	<b>100</b>	<b>100</b>

### 5.2 Subjective marking

Not applicable

### 5.3 Skill assessment specification

Section	Sub section	Criterion	Sub Criterion	Marks		
				Subjective (if applicable)	Objective	Total
A		Circuit design and/or modification			10	10
	A1		Function 70%			
	A2		Accurate using of symbols			
	A3		Provision of a Legend & marking			
	A4		Accurate using of symbols			
B		Fault finding – Hardware			10	10
	B1		Located 5 faults			
C		Measurement			15	15
	C1		Measurements wall - tolerance: +/- 3mm >500mm +/- 1mm <500mm			

Section	Sub section	Criterion	Sub Criterion	Marks		
				Subjective (if applicable)	Objective	Total
	C2		Measurements control box - tolerance: $\pm 3\text{mm}$ $>500\text{mm}$ $\pm 1\text{mm}$ $<500\text{mm}$			
	C3		Water level wall - between the marks (accuracy of the water level 1.0mm/m)			
	C4		Water level control box - between the marks (accuracy of the water level 1.0mm/m)			
		Level to be checked using the Competitor's level				
<b>D</b>		Installation wall and panel			30	30
	D1		Wall			
	D2		Control Box and panel			
<b>E</b>		Test, commissioning, and safety			5	5
	E1		Competitors make a written record (with blank paper)			
	E2		If the plant is safe? YES - Experts give voltage (If a Competitor has not completed the commissioning properly, Experts must ensure all is safe to live and mark accordingly)			
	E3		Competitors must complete the test record – under supervision of the expert group (test & comm.)			
<b>F</b>		Hardware Function (Manual operation/wiring)			10	10
	F1		Switches and fuses			
	F2		Operator panel screen overview page selection from external switch			

Section	Sub section	Criterion	Sub Criterion	Marks		
				Subjective (if applicable)	Objective	Total
	F3		Operator panel manual mode page selection from external switch			
	F4		Operating according to the given diagram / flowchart			
	F5		Bus-system wiring and function			
<b>G</b>		Software Function (Automatic operation)			20	20
	G1		Operator panel automatic mode page			
	G2		Operating according to the given diagram / flowchart			
<b>TOTAL</b>					100	100

The tolerances to be used for the measurement criteria are as follows:

- $\pm 1$  mm for any measurements between 0 and 500 mm
- $\pm 3$  mm for any measurements over 500 mm

Evaluation of cables, conductors and terminations

- Cables should be correctly selected for the application.
- There shall be no damage to cables or conductors.
- Excessive conductor should not appear at terminations.
- Conductor insulation should not be damaged by the termination.

#### Commissioning and marking

- The installation must be in compliance with safety standards, instructions and specification.
- The Competitor must complete a test certificate for the electrical installation.
- Cable ducts and covers must be securely fixed in place.
- All devices must be identified with labels.
- Competitors must provide a written record of all electrical tests including earth continuity, insulation resistance, voltage levels and phase rotation.
- The power wires to and out from the VSD and to any power supply must not be connected when the Competitor is making the insulation test.

#### For Module B

The Competitor is required to produce an I/O address list for the PLC used. The completed I/O list must be handed to the Chief Expert (or their nominee) prior to leaving the skill area on the day the PLC section is to be tested and marked.

### 5.4 Skill assessment procedures

The Expert groups will develop the appropriate marking schedules for the section of the marking criteria that they are responsible for. Each measurement of each section will be clear and unambiguous, with appropriate parameters or tolerances specified.

The prepared marking schedule must be checked and approved for use by the Experts, who must sign a set of the complete schedules before they are used.

Procedure for testing PLCs and programming software prior to being used

- Experts must be sure that PLCs are cleared prior to the Competition start and that the programming software is correctly installed.
- Experts must check that no PLC's program is copied on the Competitor's working PC.
- A seal must be put on the disk drive and the memory slot of the PLC if it has one.

Section	Criterion	Test end of day	Min. number of test groups
A	Circuit design and/or modification	C1	1
B	Fault finding – Hardware	C2	1
C	Measurement	C2	2
D	Installation wall and panel	C3	3
E	Test, commissioning, and safety	C3 or C4	3
F	Hardware Function (Manual operation/wiring)	C4	1
G	Software Function (Automatic operation)	C4	1

## 6. **SKILL-SPECIFIC SAFETY REQUIREMENTS**

Refer to Host Country Health & Safety documentation for Host Country regulations.

- Safety goggles must be worn when using power tools for drilling or cutting materials.
- Protective gloves must be worn when handling materials likely to cause injury.
- The workstation must be maintained in a safe and clean working condition.
- Electrical supply may only be connected to control panels with the permission of the Chief Expert or Deputy Chief Expert.

## 7. **MATERIALS & EQUIPMENT**

### 7.1 **Infrastructure List**

The Infrastructure List details all equipment, materials and facilities provided by the Host Country.

The Infrastructure List is online (<http://www.worldskills.org/infrastructure/>).

The Infrastructure List specifies the items & quantities requested by the Experts for the next Competition. The Competition Organiser will progressively update the Infrastructure List specifying the actual quantity, type, brand/model of the items. Items supplied by the Competition Organiser are shown in a separate column.

At each Competition, the Experts must review and update the Infrastructure List in preparation for the next Competition. Experts must advise the Technical Director of any increases in space and/or equipment.

At each Competition, the Technical Observer must audit the Infrastructure List that was used at that Competition.

The Infrastructure List does not include items that Competitors and/or Experts are required to bring and items that Competitors are not allowed to bring – they are specified below.

## 7.2 **Materials, equipment and tools supplied by Competitors in their toolbox**

All sponsored automation equipment and software will be provided to the registered Experts or Member for distribution to the Competitors or responsible training organisation a minimum 9 months before the Competition.

The following materials, equipment and tools are to be brought to the Competition by the Competitor:

- All necessary hand-tools of the trade required to complete the project, including battery drills.

The Competition Organiser will ensure that Competitor computers/laptops are installed and operating independent to any external network. The PLC, HMI and VFD programming and configuration software will be installed (in multiple languages) and will be tested for all communications options required by the Competitors to work with the supplied hardware.

The computer/laptop will be of sufficient capacity to run all the programming software simultaneously at an optimal speed. This will require a specification from the software supplier at the time of the competition setup (Siemens for 2013) to be met or exceeded.

Computer screen must be 1920 \* 1080 and 24" minimum

## 7.3 **Materials, equipment and tools supplied by Experts**

Not applicable

## 7.4 **Materials & equipment prohibited in the skill area**

- Preformed templates
- Mobile phones
- Memory storage devices for PC or PLC programs.


## 7.5 **Proposed workshop and workstation layouts**

Instructions for building the electric power supply for each Competitor will be integrated into the workshop layout which will be available on the WSI website 3 months before the Competition. Basic rule is that workstation electric supplies will be provided for each Competitor with RCD's (leakage current switches)

Workshop layouts from London are available at:  
[http://www.worldskills.org/index.php?option=com\\_halls&Itemid=540](http://www.worldskills.org/index.php?option=com_halls&Itemid=540)



Workshop layout:



## 8. MARKETING THE SKILL TO VISITORS AND MEDIA

### 8.1 Maximising visitor and media engagement

Following are examples of how this skill could maximise visitor and media engagement:

- The main Test Project will reflect an automated working plant
- Each Competitor will construct an active visualisation image of the automated plant which will be visible to visitors and media
- All Competitor profiles can be shown on a common screen for visitors and media

### 8.2 Sustainability

- Recycling
- Use of 'green' materials
- Use of completed Test Projects after Competition